



March 18, 2024

ADDENDUM ONE

Forest Preserve Headquarters Roof Replacement Bid FP#24-0401

Bid Opening: April 2, 2024

This addendum is issued to modify, clarify, or correct the original Bid Solicitation and is hereby made part of the contract documents.

REVISIONS

1. In Section III "Information Sheet" under "General Scope of Work" and on the "Headquarters Building Roof Plan", the following changes or additions were made to include:

CHANGE

- Base Sq Ft building measurement should be 8,100 instead of 7,700. (This new amount also does not include any additional waste amount factored in).
- Installation of two (2) rows of Ice & Water Barrier shall be required ("WinterGuard").

ADDITION

- Continuous Ridge Vent should be based on 92 LF and Hip/Ridge Cap should be based on 272 LF.

Bidders must acknowledge this addendum one, and any future addendums, on the bid form or the bid may be rejected.

Any questions should be directed to Vaughn Stamm, Director of Operations, 5500 Northrock Drive, Rockford, Illinois 61103 or by telephone 815-877-6100 or email vstamm@winnebagoforest.org.

END OF ADDENDUM ONE